



Certificate of Type-Examination 182330006/AA/01



Issued 11-10-2022

Replaces 182330006/AA/00
Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 1a registration.

| | |
|----------------------|------------------|
| Product description: | Radio linked PIR |
| Trademark: | Secvest |
| Type designation: | FUBW50100 |
| Hardware / Software: | 13 / 1.06 |
| Variants: | See Annex 3 |

Placed on the market under the name or trademark of:

| | |
|---------------------------|------------------------------------|
| Name of the manufacturer: | Abus Security Center GmbH & Co. KG |
| Address: | Linker Kreuthweg 6 |
| City: | 86444 Affing |
| Country: | Germany |

This certificate is granted to:

| | |
|---------------------------------|------------------------------------|
| Name of the certificate holder: | Abus Security Center GmbH & Co. KG |
| Address: | Linker Kreuthweg 6 |
| City: | 86444 Affing |
| Country: | Germany |

Ron Scheepers
Managing director

Telefication B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

This certificate has THREE Annexes.



Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

Power supply type: C

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.
Electromagnetic emission and safety aspects are not covered by this certificate.

Documentation lodged for this Certificate of Type-Examination

Test Reports:

- Telefication: 180301136-001-Ver 2.00, 12 June 2018
- Telefication B.V.: 210300554-001-Ver 2.00, 16 February 2022
- CNPP: AH200067 - XCELRFR NF A2P, 07 October 2020
- CNPP: LE 20 00 19 RevA_XCELRFR_Env, 04 February 2022
- CNPP: LM 20 00 20 - XCELRFR EMC, 05 March 2020
- Telefication B.V.: 210300554-002-Ver. 1.00, 05 September 2022

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

| | |
|--------------|----------------|
| EN 50131-2-2 | November, 2017 |
| EN 50131-5-3 | March, 2017 |

Applied Standards

| | |
|---------------------|---------------|
| EN 50130-5 | June, 2011 |
| EN 50131-6+A1 | June, 2021 |
| EN 50131-1+A1+A2+A3 | June, 2020 |
| EN 50130-4+A1 | October, 2014 |

The product as described in this certificate includes the following type designations

- Product description: Radio linked PIR
- Trademark: Secvest
- Type designation: FUBW50100
- Hardware version: 13
- Software version: 1.06

- Product description: Radio linked PIT - Pet Tolerant
- Trademark: Secvest
- Type designation: FUBW50110
- Hardware version: 12
- Software version: 1.06