

# SKG-IKOB PRODUCTCERTIFICATE

## 697.393.03

Date of issue: 20-01-2025



### Certificate holder

ABUS Security Center GmbH & Co. KG

Linker Kreuthweg 5

D-86444 Affing

T: +49 82 07 959 90-0

E: info.de@abus-sc.com

I: www.abus-sc.com



### Declaration of SKG-IKOB

This certificate has been issued on the basis of BRL 3104 in accordance with the SKG-IKOB Regulations for Attestation, Certification and Inspection.

SKG-IKOB declares that the by or on behalf of the certificate owner produced building hardware product:

### Oval cylinder single OR double electro mechanical

delivered under logo / brand:

### ABUS

delivered under type- and / or article number:

**ACNP00001 , ACNP00002 , ACNP00003 , ACNP00004 , ACNP00005 , ACNP00006  
TTSKO\***

meets class 3 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

For SKG-IKOB

A handwritten signature in blue ink, consisting of a stylized 'H' and 'A' followed by a long horizontal line.

ir. H.A.J. van Dartel  
Certification manager

Verify at [www.sterrenwijzer.nl](http://www.sterrenwijzer.nl) if this certificate is still valid and actual.  
This certificate contains 2 pages.

SKG-IKOB Certificatie  
Poppenbouwing 56  
4191 NZ Geldermalsen

Postbus 202  
4190 CE Geldermalsen

T 088-2440100  
[info@skgikob.nl](mailto:info@skgikob.nl)  
[www.skgikob.nl](http://www.skgikob.nl)

CERTIFICATE

# SKG-IKOB PRODUCTCERTIFICATE

ABUS Security Center GmbH & Co. KG  
Number: 697.393.03

page 2 of 2

## 1. PRODUCT

Oval cylinder single OR double electro mechanical

## PRODUCT TYPE

cylinder

## 2. TECHNICAL SPECIFICATION

Operating:	Electronical operation
Construction:	single with a lockable knob double with on both sides a lockable knob
System:	knob with full length plug, coupled with de cam by electronic operation
	operation by: - Mifare Desfire Transponder
Material:	cylinder body: brass with various coatings
Dimension:	35x20 mm
Fixing:	2x M5
Intended use:	The electromechanical product is operated electronically by means of the options as mentioned under "System". The operating options mentioned below, as well as the lock, are included in the Self-declaration - additional product requirements for electromechanical and electronic Hinges and Locks; dated 16-01-2025, with which the certificate holder declares that the applicable requirements are met.  in combination with cylinder mortice locks and security furniture

## 3. DELIVERY

The preconditions for correct installation and the fasteners to be used are described in the enclosed or digitally published installation instructions with the following version:  
2024-06-18

## 4. PERFORMANCES

A Oval cylinder single OR double electro mechanical according this certificate fulfils the relevant requirements of BRL 3104.

A window- or door set, in which this Oval cylinder single OR double electro mechanical is installed according the installation instructions of the certificate holder meets at least burglar resistance class (RC) 3 of NEN 5096 and EN 1627, if:

- the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are fulfilled.

A window or door, in existing buildings, in which this Oval cylinder single OR double electro mechanical is installed according the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

- the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).