

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance 2831-CPR-F4918

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s).

FURM60000 – Radio Linked Smoke Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Abus Security Center GmbH & Co. KG
Linker Kreuthweg 5
Affing
Germany
86444

Digital Lighting Co., Ltd
Life Safety Division
Xinmin District
Chang'an Town
Guangdong Province, China
523879

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 14604:2005/ AC:2008 – Domestic Alarms – Smoke Alarm Devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 06 June 2024 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Technical Manager

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 06 June 2024

Issue Date: 06 June 2024

Issue Number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie



BRE Global Ireland

Approved Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F4918

FURM60000 – Radio Linked Smoke Detector

Notes:

- Battery types approved with this smoke alarm:
 - Duracell Procell MN1500 AA 1.5V Alkaline cells
 - Eveready Energizer E91 AA 1.5V Alkaline cells
- Radio link functionality is not included with the scope of approval

P Halligan, Technical Manager

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 06 June 2024

Issue Date: 06 June 2024

Issue Number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie